



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516

Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/22/2017. The results are tabulated on the attached data pages for the following client designated project:

HTPS-Amsterdam Elementary School / PR-171031-1172

The reference number for these samples is EMSL Order #011709407. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709407
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (856) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172**

Analytical Results

Client Sample Description AES-30-1118-01
 AES-HGYM-WC1; WF; Hallway Across
 From Kitchen; Higher Unit
Collected: 11/18/2017 **Lab ID:** 011709407-0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-02
 AES-HGYM-WC2; WF; Hallway Across
 From Kitchen; Lower Unit
Collected: 11/18/2017 **Lab ID:** 011709407-0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-03
 AES-KITCHEN-FP; Sink Faucet; Kitchen;
 Food Prep
Collected: 11/18/2017 **Lab ID:** 011709407-0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.53	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-04
 AES-1-STAFF-WR-TF; Sink Facuet; Staff
 Work Room/Copy Room
Collected: 11/18/2017 **Lab ID:** 011709407-0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.03	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-05
 AES-1-1-SB; Bubbler on Sink; Room 1
Collected: 11/18/2017 **Lab ID:** 011709407-0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-06
 AES-1-1-CF; Sink Faucet; Room 1
Collected: 11/18/2017 **Lab ID:** 011709407-0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-07
 AES-1-H1-WC1; WF; Hallway at Room 1;
 Lower Unit (L)
Collected: 11/18/2017 **Lab ID:** 011709407-0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709407
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172**

Analytical Results

Client Sample Description AES-30-1118-08
 AES-1-H1-WC2; WF; Hallway at Room 1;
 Lower Unit (R) **Collected:** 11/18/2017 **Lab ID:** 011709407-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-09
 AES-1-2-SB; Bubbler on Sink; Room 2 **Collected:** 11/18/2017 **Lab ID:** 011709407-0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-10
 AES-1-2-CF; Sink Faucet; Room 2 **Collected:** 11/18/2017 **Lab ID:** 011709407-0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-11
 AES-1-3-SB; Bubbler on Sink; Room 3 **Collected:** 11/18/2017 **Lab ID:** 011709407-0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-12
 AES-1-3-CF; Sink Faucet; Room 3 **Collected:** 11/18/2017 **Lab ID:** 011709407-0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-13
 AES-1-4-SB; Bubbler on Sink; Room 4 **Collected:** 11/18/2017 **Lab ID:** 011709407-0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.28	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-14
 AES-1-4-CF; Sink Faucet; Room 4 **Collected:** 11/18/2017 **Lab ID:** 011709407-0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-15
 AES-1-KGA-SB; Bubbler on Sink; Room **Collected:** 11/18/2017 **Lab ID:** 011709407-0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709407
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172**

Analytical Results

Client Sample Description AES-30-1118-15
 AES-1-KGA-SB; Bubbler on Sink; Room
Collected: 11/18/2017 **Lab ID:** 011709407-0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-16
 AES-1-KGA-CF; Sink Faucet; Room
Collected: 11/18/2017 **Lab ID:** 011709407-0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-17
 AES-1-5-SB; Bubbler on Sink; Room 5
Collected: 11/18/2017 **Lab ID:** 011709407-0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-18
 AES-1-5-CF; Sink Faucet; Room 5
Collected: 11/18/2017 **Lab ID:** 011709407-0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.13	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-19
 AES-1-KGB-SB; Bubbler on Sink;
 Kindergarten B
Collected: 11/18/2017 **Lab ID:** 011709407-0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-20
 AES-1-KGB-CF; Sink Faucet; Kindergarten
 B
Collected: 11/18/2017 **Lab ID:** 011709407-0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-21
 AES-1-6-SB; Bubbler on Sink; Room 6
Collected: 11/18/2017 **Lab ID:** 011709407-0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709407
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172**

Analytical Results

Client Sample Description AES-30-1118-22
 AES-1-6-CF; Sink Facuet; Room 6
Collected: 11/18/2017 **Lab ID:** 011709407-0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-23
 AES-1-LIBRARY-TF; Sink Faucet; Library Office
Collected: 11/18/2017 **Lab ID:** 011709407-0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-24
 AES-1-7-SB; Bubbler on Sink; Room 7
Collected: 11/18/2017 **Lab ID:** 011709407-0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-25
 AES-1-7-CF; Sink Faucet; Room 7
Collected: 11/18/2017 **Lab ID:** 011709407-0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-26
 AES-1-8-SB; Bubbler on Sink; Room 8
Collected: 11/18/2017 **Lab ID:** 011709407-0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-27
 AES-1-8-CF; Sink Faucet; Room 8
Collected: 11/18/2017 **Lab ID:** 011709407-0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-28
 AES-1-14-SB; Bubbler on Sink; Room 14
Collected: 11/18/2017 **Lab ID:** 011709407-0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.03	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-29
 AES-1-14-CF; Sink Faucet; Room 14
Collected: 11/18/2017 **Lab ID:** 011709407-0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
--------	-----------	--------	----	-------	-----------	---------	---------------	---------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011709407

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172****Analytical Results**

Client Sample Description AES-30-1118-29
 AES-1-14-CF; Sink Faucet; Room 14
Collected: 11/18/2017
Lab ID: 011709407-0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-30
 AES-1-13-SB; Bubbler on Sink; Room 13
Collected: 11/18/2017
Lab ID: 011709407-0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.16	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-31
 AES-1-13-CF; Sink Faucet; Room 13
Collected: 11/18/2017
Lab ID: 011709407-0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-32
 AES-1-H13-WC1; WF; Hallway at Room 13;
 Higher Unit
Collected: 11/18/2017
Lab ID: 011709407-0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-33
 AES-1-H13-WC2; WF; Hallway at Room 13;
 Lower Unit
Collected: 11/18/2017
Lab ID: 011709407-0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-34
 AES-1-9-SB; Bubbler on Sink; Room 8
Collected: 11/18/2017
Lab ID: 011709407-0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-35
 AES-1-9-CF; Sink Faucet; Room 9
Collected: 11/18/2017
Lab ID: 011709407-0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011709407

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172****Analytical Results**

Client Sample Description AES-30-1118-36
 AES-1-12-SB; Bubbler on Sink; Room 12
Collected: 11/18/2017 **Lab ID:** 011709407-0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.37	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-37
 AES-1-12-CF; Sink Facuet; Room 12
Collected: 11/18/2017 **Lab ID:** 011709407-0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.12	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-38
 AES-1-10-SB; Bubbler on Sink; Room 10
Collected: 11/18/2017 **Lab ID:** 011709407-0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-39
 AES-1-10-CF; Sink Facuet; Room 10
Collected: 11/18/2017 **Lab ID:** 011709407-0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.06	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-40
 AES-1-11-SB; Bubbler on Sink; Room 11
Collected: 11/18/2017 **Lab ID:** 011709407-0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.09	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-41
 AES-1-11-CF; Sink Faucet; Room 11
Collected: 11/18/2017 **Lab ID:** 011709407-0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-42
 AES-1-FACULTY-TF; Sink Faucet; Staff Dining Room
Collected: 11/18/2017 **Lab ID:** 011709407-0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011709407
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172**

Analytical Results

Client Sample Description AES-30-1118-43
 AES-1-MO-TF; Sink Faucet; Main Office;
 Work Room
Collected: 11/18/2017 **Lab ID:** 011709407-0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.07	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-44
 AES-1-NURSE-CF; Sink Faucet; Nurse's
 Office; Exam Room
Collected: 11/18/2017 **Lab ID:** 011709407-0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.79	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-45
 AES-1-NURSE-NBR; Sink faucet Nurse's
 Office; Restroom
Collected: 11/18/2017 **Lab ID:** 011709407-0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.34	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-46
 AES-1-15-SB; Bubbler on Sink; Room 15
Collected: 11/18/2017 **Lab ID:** 011709407-0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.85	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-47
 AES-1-15-CF; Sink Faucet; Room 15
Collected: 11/18/2017 **Lab ID:** 011709407-0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.93	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-48
 AES-1-H16-WC1; WF; Hallway Across
 From Room 16: Higher Unit
Collected: 11/18/2017 **Lab ID:** 011709407-0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-49
 AES-1-H16-WC2; WF; Hallway Across
 From Room 16; Lower Unit
Collected: 11/18/2017 **Lab ID:** 011709407-0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011709407

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172****Analytical Results**

Client Sample Description AES-30-1118-50
 AES-1-17-SB; Bubbler on Sink; Room 17
Collected: 11/18/2017 **Lab ID:** 011709407-0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.32	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-51
 AES-1-17-CF; Sink Facuet; Room 17
Collected: 11/18/2017 **Lab ID:** 011709407-0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-52
 AES-1-24-SB; Bubbler on Sink; Room 24
Collected: 11/18/2017 **Lab ID:** 011709407-0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-53
 AES-1-24-CF; Sink Facuet; Room 24
Collected: 11/18/2017 **Lab ID:** 011709407-0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-54
 AES-1-23-SB; Bubbler on Sink; Room 23
Collected: 11/18/2017 **Lab ID:** 011709407-0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-55
 AES-1-23-CF; Sink Faucet; Room 23
Collected: 11/18/2017 **Lab ID:** 011709407-0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.14	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-56
 AES-1-18-SB; Bubbler on Sink; Room 18
Collected: 11/18/2017 **Lab ID:** 011709407-0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-57
 AES-A-18-CF; Sink Faucet; Room 18
Collected: 11/18/2017 **Lab ID:** 011709407-0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011709407

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172****Analytical Results**

Client Sample Description AES-30-1118-57
 AES-A-18-CF; Sink Faucet; Room 18
Collected: 11/18/2017
Lab ID: 011709407-0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-58
 AES-1-19-SB; Bubbler on Sink; Room 19
Collected: 11/18/2017
Lab ID: 011709407-0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.02	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-59
 AES-1-19-Sink Faucet; Room 19
Collected: 11/18/2017
Lab ID: 011709407-0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.23	1.00	µg/L	12/1/2017	SM	12/1/2017	SM

Client Sample Description AES-30-1118-60
 AES-1-22-SB; Bubbler on Sink; Room 22
Collected: 11/18/2017
Lab ID: 011709407-0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/4/2017	SM	12/4/2017	SM

Client Sample Description AES-30-1118-61
 AES-1-22-CF; Sink Faucet; Room 22
Collected: 11/18/2017
Lab ID: 011709407-0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/4/2017	SM	12/4/2017	SM

Client Sample Description AES-30-1118-62
 AES-1-21-SB; Bubbler on Sink; Room 21
Collected: 11/18/2017
Lab ID: 011709407-0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/4/2017	SM	12/4/2017	SM

Client Sample Description AES-30-1118-63
 AES-1-21-CF; Sink Faucet; Room 21
Collected: 11/18/2017
Lab ID: 011709407-0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.63	1.00	µg/L	12/4/2017	SM	12/4/2017	SM

Client Sample Description AES-30-1118-64
 AES-1-20-SB; Bubbler on Sink; Room 20
Collected: 11/18/2017
Lab ID: 011709407-0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011709407

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 11/22/17 3:00 PM

Project: **HTPS-Amsterdam Elementary School / PR-171031-1172****Analytical Results**

Client Sample Description AES-30-1118-64
 AES-1-20-SB; Bubbler on Sink; Room 20
Collected: 11/18/2017
Lab ID: 011709407-0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/4/2017	SM	12/4/2017	SM

Client Sample Description AES-30-1118-65
 AES-1-20-CF; Sink Faucet; Room 20
Collected: 11/18/2017
Lab ID: 011709407-0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/4/2017	SM	12/4/2017	SM

Client Sample Description AES-30-1118-66
 QC Blank; DI Blank
Collected: 11/18/2017
Lab ID: 011709407-0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/4/2017	SM	12/4/2017	SM

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)