

Attachment L - Results Summary Lead in Water Sample

School Name: **Hillsborough Elementary School** (12-20-17 data, only)

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
HES-1-16-DW	HES-13-1220-01	WF; Room 16	24.0	Yes
HES-1-8-DW	HES-13-1220-02	Bubbler on sink; Room 8	395	Yes
HES-1-7-DW	HES-13-1220-03	Bubbler on sink; Room 7	18.2	Yes
HES-1-102-DW	HES-13-1220-04	WF; Room 102	64.9	Yes
HES-1-113-SB	HES-13-1220-05	WF; Room 113	19.7	Yes
HES-1-112-DW	HES-13-1220-06	WF; Room 112	35.8	Yes
HES-1-104-DW	HES-13-1220-07	WF; Room 104	23.5	Yes
HES-1-111-DW	HES-13-1220-08	WF; Room 111	6.61	No
HES-1-110-DW	HES-13-1220-09	WF; Room 110	9.87	No
HES-1-108-DW	HES-13-1220-10	WF; Room 108	19.7	Yes
QC BLANK	HES-13-1220-11	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported